

Obverse



**FIRE PROTECTION
EQUIPMENT
OUT OF SERVICE**

Authorized by (Signature) Date

Protection system impaired:

This valve/device controls:

Area protected:

Estimated date/time of restoration:

Time system taken out of service:

Time system restored to service:

Time security/alarm company notified:

Time fire department notified:

Time Axis US Property notified:

Check list completed (see reverse of tag):

YES NO

Drain test results (for water-based systems)

Static psi

Residual psi

Reverse



**FIRE PROTECTION
EQUIPMENT
OUT OF SERVICE**

Fire Protection Impairment Checklist

- Inform department heads in building or areas where fire protection is out of service
- Shut down hazardous operations or processes
- Extend smoking restrictions to affected area and 25' beyond
- Notify fire brigade or shift captains
- Supplement manual fire protection with auxiliary fire extinguishers and/or charged hose lines
- Provide continuous fire watch throughout affected area
- Position individual at closed valve in event of emergency

**FIRE PROTECTION
EQUIPMENT
OUT OF SERVICE**